

SERVICE REPORT / CERTIFICATE

CUSTOMER NAME: Norwich Astronomical Society	JOB NUMBER: 100322/1
SITE ADDRESS: Toad Lane, Thwaite St Mary Norfolk, NR35 2EQ	INVOICE ADDRESS:


WORK CARRIED OUT								
EQUIPMENT	SIZE	VISUAL INSPECT	BASIC SERVICE	EXT SVC O/HAUL	RE-CHARGE	SERVICE EXCH.	SUPPLY NEW	EXTING DISPOSAL
WATER	6 ltr							
	9 ltr							
WATER ADDITIVE	3 ltr							
	6 ltr							
	9 ltr							
CO2	2 kg		1					
	5 kg							
FOAM	2 ltr							
	3 ltr							
	6 ltr		8					
	9 ltr							
WET CHEMICAL	3 ltr							
	6 ltr							
POWDER	1 kg							
	2 kg							
	4 kg							
	6 kg							
	9 kg							
P50 FOAM	2 ltr							
	6 ltr							
	9 ltr							
MULTIFOAM	0.6							
FIRE BLANKET								
TOTAL			9					

PARTS / EQUIPMENT SUPPLIED	
ITEM	QUANTITY
ANTI -TAMPER SEAL	9
PRESSURE GAUGE INDIC	8
SERVICE LABEL	
SAFETY PIN/CLIP	
HEADCAP WASHER	
HOSE O RING	1
CO2 HORN/HOSE	
WATER/FOAM HOSE	
WALL FIXINGS/BRACKET	
BASE PLATE	
EXTINGUISHER ID SIGN	
EXTINGUISHER STAND	
EXTINGUISHER BOX	
EXTINGUISHER COVERS	
SMOKE/CM DETECTOR	
FIRE CALL POINT ID SIGN	
FIRE ACTION NOTICE	
MEANS OF ESCAPE SIGN	
ASSESEMBLY POINT SIGN	
FIRE RISK ASSESSMENT	
FIRE LOG BOOK	

DUTY OF CARE WASTE (NOTE)
The customer hereby authorises that APF Safety Services Ltd to dispose extinguishers removed from site through a waste agent. Our Waste Carriers Licence No. CBDU237016 - Envir Agency

OBSERVATIONS & RECOMMENDATIONS:

APF Safety Services Ltd have serviced the portable fire extinguishers within the premises identified above in accordance with the requirements and frequencies indicated by BS:5306 part 3 . Where dry powder extinguishers are installed the customer accepts responsibility for any secondary damage caused to people and processes.
Under BS:5306 part 3, your are required to visually inspect extinguishers at monthly intervals.

DATE OF SERVICE 10/03/2022	TECHNICIAN A.P Fitches 	<h1>Stamp</h1>
	LOG BOOK COMPLETED No	