

**SERVICE REPORT / CERTIFICATE**

<b>CUSTOMER NAME:</b> Norwich Astronomical Society	<b>JOB NUMBER:</b> 170223/1
<b>SITE ADDRESS:</b> Seething Observatory, Toad Lane, Thwaite St Mary, Norfolk, NR35 2EQ	<b>INVOICE ADDRESS:</b> As site

WORK CARRIED OUT										
EQUIPMENT	SIZE	VISUAL INSPECT	BASIC SERVICE	EXT SVC O/HAUL	RE- CHARGE	SERVICE EXCH.	SUPPLY NEW	EXTING DISPOSAL		
WATER	6 ltr									
	9 ltr									
WATER ADDITIVE	3 ltr									
	6 ltr									
	9 ltr									
CO2	2 kg		1							
	5 kg									
FOAM	2 ltr									
	3 ltr									
	6 ltr		8							
	9 ltr									
WET CHEMICAL	3 ltr									
	6 ltr									
POWDER	1 kg									
	2 kg									
	4 kg									
	6 kg									
	9 kg									
P50 FOAM	2 ltr									
	6 ltr									
	9 ltr									
MULTIFOAM	0.6									
FIRE BLANKET										
<b>TOTAL</b>			9							

PARTS / EQUIPMENT SUPPLIED	
ITEM	QUANTITY
ANTI -TAMPER SEAL	9
PRESSURE GAUGE INDIC	8
SERVICE LABEL	
SAFETY PIN/CLIP	
HEADCAP WASHER	
HOSE O RING	9
CO2 HORN/HOSE	
WATER/FOAM HOSE	
WALL FIXINGS/BRACKET	
BASE PLATE	
EXTINGUISHER ID SIGN	
EXTINGUISHER STAND	
EXTINGUISHER BOX	
EXTINGUISHER COVERS	
SMOKE/CM DETECTOR	
FIRE CALL POINT ID SIGN	
FIRE ACTION NOTICE	
MEANS OF ESCAPE SIGN	
ASSESEMBLY POINT SIGN	
FIRE RISK ASSESSMENT	
FIRE LOG BOOK	

**DUTY OF CARE WASTE (NOTE)**  
The customer hereby authorises that APF Safety Services Ltd to dispose extinguishers removed from site through a waste agent. Our Waste Carriers Licence No. CBDU237016 - Envir Agency

**OBSERVATIONS & RECOMMENDATIONS:**

APF Safety Services Ltd have serviced the portable fire extinguishers within the premises identified above in accordance with the requirements and frequencies indicated by BS:5306 part 3 . Where dry powder extinguishers are installed the customer accepts responsibility for any secondary damage caused to people and processes.  
Under BS:5306 part 3, you are required to visually inspect extinguishers at monthly intervals.

<b>DATE OF SERVICE</b> 17/02/2023	<b>TECHNICIAN</b> A.P Fitches 
	<b>LOG BOOK COMPLETED NO</b>